

1990 Energy Study done on actual home.

Run Number	Cooling Mode			
	Electric Input**	Number of Cycles	Number of Damper Cycles	
			Zone 1	Zone 2
SINGLE ZONE	3,685	6,341	N/A	N/A
SINGLE ZONE & SETBACK	3,160	4,148	N/A	N/A
TWO ZONE NO SETBACK	3,964	6,860	5,585	4,097
TWO ZONE & SETBACK	3,278	4,223	3,454	2,459
4 ZONE & ALT. SETBACK	3,344	6,504	5,624	1,951
4 ZONES & 2 SETBACKS/DAY	3,283	5,903	4,706	2,132

No Comfort & No Savings

Savings but No Comfort

Comfort & Extra Cost

Comfort & Savings

11% Electric Input Savings

33% Fewer Air Conditioner Cycles